

# SARTELL SEWER & WATER APPLICATION & INSPECTION REPORT

A permit and inspection is required whenever there is a new installation or replacement of a water and sewer lines to a structure (even a portion). The fee for this permit is \$51.00. The permit fee shall not be required when the installation of the water and/or sewer services is part of a more comprehensive permit (for the construction of new house, for instance); however, these inspections and this report are still required in such cases.

Property Owner: \_\_\_\_\_ Permit # \_\_\_\_\_

Property Address: \_\_\_\_\_

Inspection Date: \_\_\_\_\_ Contractor: \_\_\_\_\_

## WATER SERVICE

- \_\_\_\_\_ Size of Pipe is at least 1" in diameter
- \_\_\_\_\_ Copper Pipe: K Type
- \_\_\_\_\_ No. of splices (should be none if less than 100')
- \_\_\_\_\_ Plastic: series 160 PE (polyethylene) or Better
- \_\_\_\_\_ The entire line appears to be buried at least as deep as the current depth at the curb stop
- \_\_\_\_\_ Pressure of 100 psi must be sustained for fifteen minutes
- \_\_\_\_\_ Min. 18 AWG blue tracer wire

## SEWER SERVICE

- \_\_\_\_\_ No. 45® bends, with good cause
- \_\_\_\_\_ Pipe Diameter (min. of 4")
- \_\_\_\_\_ Any excessive deflection, or poor bedding for pipe?
- \_\_\_\_\_ Schedule 40 PVC or heavier
- \_\_\_\_\_ Pressure of 5 psi must be sustained for 15 minutes
- \_\_\_\_\_ Distance of clean out from the structure. There must also must be one cleanout every 100 feet.
- \_\_\_\_\_ Does the line *appear* to have necessary slope? Contractor responsible for slope of at least ¼" per 4"

## GENERAL

- \_\_\_\_\_ Must be at least 1' vertical separation between water and sewer services
- \_\_\_\_\_ If there are any relevant notes, but sure to make comments on the back of this page and indicate here whether or not there are additional comments on the back of this page.
- \_\_\_\_\_ Pictures of sewer and water service at time of hook-up

The Building Inspector's signature below indicates approval of this Permit. This inspection is done exclusively for the protection of the interests of the City, particularly as it relates to the operation of its water and sewer utilities. The City is in no way certifying for the sake of the property owner or the contractor that they work was performed in an acceptable manner. By virtue of the Installer/Contractor's signature below they are acknowledging that they have constructed the services in conformance with the standards contained on this Permit form.

\_\_\_\_\_  
City of Sartell

\_\_\_\_\_  
Date

\_\_\_\_\_  
Installer/Contractor

\_\_\_\_\_  
Date